



February 12, 2026
Reference: 522617

To
Niv Saidman
VP Marketing
Saidman engineering Ltd

Re: **Product approval for use with drinking water**

Based on SII test certificates no. 7012202926 and 7512218195
for complying with the requirements of SI 5452 (2022)

In accordance with the guidelines of the Israeli Ministry of Health, and following the testing of a representative sample of the product and receiving the relevant information, we have no objection to the use of coating material type "ARC 855", manufactured by "A.W. CHESTERTON", USA, for use in drinking water applications at temperatures of up to 40°C.

Any change to the product or its composition requires further evaluation and re-approval.

This letter does not constitute a recommendation to use the aforementioned product and may not be used for advertising or published in mass media.

This approval is valid until October 28, 2030.

Sincerely,
Assaf Amram
Head of the Water section
Chemistry, Food and Water Branch

The information in this approval will be published on the SII site's search engine for drinking water (SI 5452)

This document is not approval for marking the product with the Standards Mark