

# **Axial Turbine Pump**

Chemical Processing — Cooling Systems
ARC 855 and 858 Coating
Case Study 035

# Challenge

#### Issue

Concrete encased pump could not be removed for repair. Extensive cavitation and pitting corrosion reduced pump flow performance impacting plant efficiency.

#### Goals

- Repair in place with solution that provides long term protection at 50% of previous repair cost
- Extend MTBR to >10 years

#### **Root Cause**

A combination of cavitation and pitting corrosion attacked the pump's cast iron bell housing. Tolerances went out-of-spec due to metal loss of .750" (18 mm). Empirical data indicated pending catastrophic failure lower bell housing.



Three pumps were experiencing this failure

# **Solution**

### **Preparation**

- Decontaminate surfaces
- Grit blast to Sa 2.5 with 3 mils (75 μm) angular profile

## **Application**

- Apply ARC 858 to zones of pitting corrosion and cavitation
- 2. Apply ARC 855 in 2 coats to total DFT of 30-40 mils (.75-1 mm)

Cavitation and erosion of bell housing

# **Results**

## **Client Reported**

- Pumps have performed to expectations for 10+ years
- Each pump required 3 days to complete repairs

# **Client Reported Savings**

Off site coating repairs (per pump): \$15.0K

Onsite ARC repairs (per pump): -\$ 2.7K

Total savings per pump: \$12.3K

Total savings based on 3 pumps: \$36.9K

\$=USD



Damaged area repaired with ARC 858