



July 09, 2025  
Reference: 522537

To  
Niv Saidman  
VP Marketing  
Saidman Engineering Ltd

Re: **Product approval for use with drinking water**

Based on SII test certificate no. 7512210756  
for complying with the requirements of SI 5452 (2022)

In accordance with the instructions of the Israeli Ministry of Health, and after testing a representative sample of the product and receiving the relevant information, we have no objection to the use of the coating material type "ARC S1 PW BLU", manufactured by "A. W. Chesterton CO", U.S.A, for use in drinking water applications at temperature up to 40°C.

Any modification of the product or its composition requires further examination and re-approval.

This correspondence does not constitute a recommendation to use the mentioned product and should not be published in the mass media.

This approval is valid until June 03, 2030.

Sincerely,  
Assaf Amram  
Head of Water section  
Chemistry, Food and Water Branch

The information in this approval will be published in "search engine drinking water SI 5452" on the SII site

**This document is not approval for marking the product with the Standards Mark**

**Chemistry, Food and Water Branch**, 42 Chaim Levanon St, Tel Aviv 6997701 Israel,  
Tel: 972-3-6465138, Fax: 972-3-6465036, E-mail: for food: food@sii.org.il, for wine: wine@sii.org.il, for food  
contact materials: fcm@sii.org.il, for water: water@sii.org.il, www.sii.org.il